



# Backflow Prevention




Is a hose attached to the mop sink?



No further action required.




Splitter?



An AVB is **required** on a free hanging hose, **not** a chemical tower hose.

AVB



No further action required.

**Maintain adequate backflow prevention!**

If you have a spray nozzle attached or more complicated mop sink set-up, contact a plumber or Mesa County Public Health.



**MESA COUNTY  
PUBLIC HEALTH**  
*Working Together for a Healthy Community*

For additional food safety resources go to  
[www.health.mesacounty.us](http://www.health.mesacounty.us)  
(970) 248-6900