






# Backflow Prevention


Is a hose attached to the mop sink?



No further action  
required



An AVB is **required** on a free hanging hose, **not** a chemical tower hose.



No further action

**Be sure your mop sink is safe!**

If you have a spray nozzle attached or more complicated mop sink set-up contact a plumber or Mesa County Health Department.



**MESA COUNTY  
HEALTH DEPARTMENT**

*Working Together for a Healthy Community*

For additional food safety resources go to  
[www.health.mesacounty.us/environment](http://www.health.mesacounty.us/environment)  
(970) 248-6900